

IEQ SCHOOL DATA BASE

School Name: Applications and Research Lab **Principal:** Karl Schindler **DATE:** 1/10/17

IEQ Team Leader: Rod Pratesi **IEQ System Leader:** Greg Maciulla

11. Limited use of non-issued HCPSS furniture and appliances	61,B-55,B-48,B-2,,B-10,B-4,B-17,B-28,A-1,A-3,A-8,A-9,A-10,A-15,A-16,A-18,A-20,C-39,C-31,C23,C-27,C-26,C-6,C-	maker,rug,fridge,microwave,carpet,mini fridge,microwave,fridge,microwave,rug,flowers,lamp, lamp,flowers,heater,heater,teapot,flowers, heaters,lamp,plants,fan,fridge,lamps,furniture,heater,flower,microwave,toaster,coffe maker,lamp,fridge,microwave,fan,fridge,coffee maker,rug,plants,coffee maker,fridge coffee	xxxx					
12. No excessive fabric materials, stuffed animals, beanbags, pillows, etc.	A-2,A-8,A-18,D-21,B63,B-61,B-41,B-39,B-63,B-64,B-59,B-60,B-49,B-14	pillow,stuffed animals,toys on beam,stuffed animal, DNA paper hanging too close to ceiling,top shelf cleared,shelving in closet too high,stuffed animals,top shelf cleared, remove paper from shelf,plant in front of electrical box,shelving	xx					
13. No structural or physical gaps around exit doors	C-35,C-39,C-28, A-9,A-10,A-16,A-20,B-33, B-31,B-27,B-28,B-8,B-46d, B-lobby,D-hall way,printshop,D-21,grounds	Door gaps, door gaps, rust and corrosion, broken window at top of door,leaky windows, door gap,door gap,Door gap and weather stiping replaced,rust,rust, broken window, window seal,Water damage rear door, stained window and signs of water in the window,hallway doors have caul separation,printshop door leaks and gaps,door gap,all doors need sweeps		xxxx	17279/17289/17291	17279-1/12/17	17289-1/18/2017	17291-1/17/17
14. No improperly stored materials/chemicals	B-17,C-35,C-46	Cleaning products,borax, chemicals,	xx					
15. Floor coverings are level and secure (tile, carpets, wood board, etc.)	B-61,B-2,B-47,B-31	tiles on floor coming up,holes in tiles,stained and holes in tile,tile popping,	x					
16. Barrier mats vacuumed well								
17. Fish tanks are clean and located away from vents/thermostats	C-46	Fishtank dirty(this is the Entomologist room)	x					
18. Waterproof barriers in place for plants and no standing water	boiler room,D-11,grounds/custodial repair room, grounds	roof leaks,pipes rusted at fan,		x				
19. Sinks and fountains drain quickly and work properly including absence of leaks	boiler room	drains need extension		x				
20. No standing water in sinks, fountains, on counter	A-10	dry trap,		x				
21. Carpet dry nearby sinks, fountains								

IEQ SCHOOL DATA BASE

School Name: Applications and Research Lab **Principal:** Karl Schindler **DATE:** 1/10/17

IEQ Team Leader: Rod Pratesi **IEQ System Leader:** Greg Maciulla

33. No broken windows								
34. Windows are closed								
35. Exterior doors are closed								
36. No pools of standing/stagnant water								
37. Exterior veneer intact								
38. Outside lights working and intact								
39. Gutters and downspouts clear/working								
40. No stains from roof on outside walls								
41. Bins from garbage and recycling clearly marked								
42. Hard surfaces (sidewalks, etc.) cleared of any turf application								
43. Proper maintenance of planted beds and other vegetation								
44. Landscaping and turf look healthy and disease free								

COMMENTS:

Temperature in building fluctuates drastically. Curtains throughout the building

IEQ SCHOOL DATA BASE	
School Name:	Applications and Research Lab
Principal:	Karl Schindler
	DATE: 1/10/17
IEQ Team Leader:	Rod Pratesi
	IEQ System Leader: Greg Maciulla
Unable to look closely at room C-46 the entomologist room. It's very cluttered and dirty	
Many objects in C-29 are instructional and should not be removed. This is our Hotel, Restaurant Management class.	
Parts of the C wing are for the TV studio where there are a lot of fake plants and wires running across the floor. NO students access this area.	

CLOSED	
1/14/2017	
1/27/2017	
17285-1/14/17 17274-1/12/17	
17278-1/127/17	

